









1 HEADER CONNECTION DETAIL

1 1/2" = 1'-0"

C\a060-001

## PARTITION NOTES

- (MASTER LIST ALL NOTES MAY NOT APPLY) STUDS CONTINUE TO DECK UNO. REF CAPTURE TRACK
- DETAILS 5 AND 6-A6. USE 1/2" GYPSUM BOARD ON NON-RATED PARTITIONS UNO.
- USE 5/8" TYPE X GYPSUM BOARD ON FIRE RATED PARTITIONS
- CONTINUE FINISH MATERIAL TO A MINIMUM OF 4" ABOVE
- SUSPENDED CEILING SYSTEMS UNO. WHERE NO CEILING IS INDICATED CONTINUE FINISH TO DECK

CYNTERGY ARCHITECTURE, PLI 810 S CINCINNATI

SECOND FLOOR

TULSA, OK 74119

www.cyntergy.com

STIPULATION FOR REUSE

THIS DRAWING WAS PREPARED FOR USE ON A SPECIFIC SITE AT FORT WORTH, TX CONTEMPORANEOUSLY WITH ITS ISSUE DATE ON 02/12/18, AND IT

IS ISSUE DATE ON 02/12/18, AND I IS NOT SUITABLE FOR USE ON A DIFFERENT PROJECT SITE OR AT A LATER TIME. USE OF THIS DRAWING FOR REFERENCE OR EXAMPLE ON ANOTHER PROJECT REQUIRES THE SERVICES OF PROPERLY LICENSED APOLITECTS AND ENCINEERS

REPRODUCTION OF THIS DRAWING FO

AUTHORIZED AND MAY BE CONTRARY TO THE LAW.

UNDARTH, 1
WORTH, 1

ISSUE BLOCK

02/12/18 PERMIT/ BII

30 X 42 SHEET S

DOCUMENT DATE: 02/12/18

SIGNATURE AND REQUIRED

SEAL OF AOR/EOR ARE

NOT FOR CONSTRUCTION

DOCUMENTS WITHOUT

CHECKED BY:

DRAWN BY:

PROTO CYCLE:

ARCHITECTS AND ENGINEERS.

- UNO. MAINTAIN CLEARANCE BELOW STRUCTURE PER CAPTURE TRACK DETAILS 5 AND 6-A6.
- STUD PARTITIONS REQUIRING A FIRE RATING OF ONE HOUR SHALL COMPLY WITH UL#U419, UL#U465 OR UL#U442. MASONRY PARTITIONS REQUIRING ONE HOUR FIRE RATING
- SHALL COMPLY WITH UL#U905. STUD WALLS RECEIVING PLYWOOD SHALL BE 22 GAUGE OR
- MAXIMUM HEIGHT OF NON LOAD BEARING WALL ABOVE HEADER TO BE 20'-0".
- REF SPECIFICATIONS FOR LATERAL BRACING OF STUD
- PARTITIONS. ). PROVIDE ALTERNATING DIAGONAL METAL STUD BRACING FROM DECK TO WALL STUDS ABOVE CEILING AT 48" OC FOR
- PARTITION STUDS UNDER 6" WIDE. REF BRACING DETAIL 4-A6. . USE GYPSUM BOARD BEHIND ALL FRP BOARD UNO.
- 2. WHERE NO CEILING IS SCHEDULED, STOP 1/2" PLYWOOD
- SUBSTRATE AT 10'-0" AFF. 3. PROVIDE FIRE BLOCKING AT FLOOR AND ROOF LEVELS, CONCEALED SPACES BETWEEN STAIRWAY STRINGERS,

LOCATIONS AS REQUIRED BY CODE.

4. ROOMS THAT HAVE 5/8" IMPACT RESISTANT GYP BD TO 48"

PENETRATIONS IN FLOOR/CEILING ASSEMBLIES AND OTHER

- AFF NEED 5/8" GYP BD ABOVE 48" AFF. REF PLANS FOR LOCATIONS.
- 5. ON RESTROOMS WALLS RECEIVING PORCELAIN TILE UPPER (PAINTED) PORTION IS TO BE WATER RESISTANT GYPSUM
- . WHEN MODIFYING OR BUILDING ANY NEW FIRE RATED PARTITIONS, ENSURE ALL PENETRATIONS AND JOINTS ARE SEALED IN ACCORDANCE WITH THE SPECIFICATIONS.

## PARTITION LEGEND (MASTER LEGEND - ALL TYPES MAY NOT APPLY)

BOARD IN LIEU OF GLASS-MAT BACKER MATERIAL.

- NUMBER INDICATES STUD

LETTER INDICATES PARTITION TYPE 12

NO NUMBER INDICATES STUD HEIGHT TO BOTTOM REF PLANS AND A3 OF ROOF DECK TYP SHEET A6 NUMBER INDICATES STUD SIZE AS FOLLOWS: OF ROOF DECK TYP

 $1 - 1 \frac{5}{8}$  METAL 6 - 6 METAL 2 - 2 1/2" METAL 8 - 8" CMU 3 - 35/8" METAL 12 - 12" CMU 1 HOUR RATED GYPSUM BOARD (NEW)

UL#U419, UL#U442 OR UL#U465

1 HOUR RATED CMU (NEW) UL#U905

ADJACENT WALL

-20 GAUGE CLIP

ANGLE

-20 GAUGE

TOP TRACK

-METAL STUDS

AS SCHEDULED

REF PARTITION TYPES

-WALL FINISH

AT CORNER

NON-RATED GYPSUM BOARD WALL (NEW) ACOUSTICAL INSULATION FULL WALL THICKNESS (NEW)

----- CHAIN LINK FENCE (NEW) COOLER/FREEZER WALL (NEW)

EXISTING 1 HOUR RATED GYPSUM BOARD TO REMAIN

EXISTING PARTITION OR WALL TO REMAIN CMU WALL (NEW)

EXISTING WALL TO BE DEMOLISHED EXISTING CHAIN LINK FENCE

## PARTITION TYPES

REFERENCE SIDE OPPOSITE SIDE WHERE NO CEILING IS INDICATED AND AT RATED WALLS, CONTINUE GYPSUM BOARD TO DECK METAL STUDS-USE 5/8" WATER RESISTANT

GYPSUM BOARD AT WET AREAS— 102502 C\A060-ptA

CONTINUE PLYWOOD AND GYPSUM TO DECK AT SPACES WITHOUT SECURE CEILING, UNO —— METAL STUDS - -1/2" GYPSUM BOARD, BOTH SIDES ----1/2" PLYWOOD,

BOTH SIDES ---

012706 C\a060-ptD

JAMES EDWARD TURNER ARCHITECT OF RECORD

> **PARTITION TYPES** DETAILS

A6

GYPSUM BOARD CONTROL JOINT

1 1/2" = 1'-0"

C\a060-002

VERTICAL GYPSUM BOARD
CONTROL JOINT
REF SPECIFICATIONS